



CITY OF LODI

PUBLIC WORKS DEPARTMENT

Domestic Water Service (3", 4", 6" & 8") Materials List

- [1] FLG Spool, 24" long (2 ea) (C.I., D.I., or steel)
- [2] FLG x Plain end spool (2 ea) Leave 1" gap at coupling
- 3" - 15" long
 - 4" - 15" long
 - 6" - 20" long
 - 8" - 20" long
- ends of spools
(C.I. or steel)

Christy or Bes Box	Lid (Traffic)		Box Extension
	Christy	Bes	
3"+4" B-48 or C48W	B48-62D	62D85	10" Box Extension B48 x 10
6"+8" B-52 or C52W	B52-62D	62D90	10" Box Extension B52 x 10

- [4] FLG Spool, lengths as needed (optional) (C.I., D.I., or steel)
- [5] Temporary Blowoff per Std Plan 409. 2" for 4"-6" service,
4" for 8" and larger service.

All fittings shall be cast or ductile iron or steel (as noted) and shall conform to applicable AWWA Standards. (Sch. 40, 150 lb. FLG)

Traffic Lids shall be used in all location.

Sheet 2 of 2

Dr. KT	No.	Date	Revision	Appr.	Approved By:		STD PLAN
Ch. WS					<i>F. Wally Sandelin</i>	12/28/00	406
Date 12/00					F. Wally Sandelin City Engineer R.C.E. 39895	Date	